Wisconsin Department of Safety and Professional Services
Division of Industry Services
1400 East Washington Avenue
PO Box 7302
Madison WI 53707-7302

Phone: 608-266-2112
Web: http://dsps.wi.gov
Email: dsps@wisconsin.gov

Double Check/DC Detector Performance Test

Personal information you provide may be used for secondary purposes [Privacy Law, s.1504 (1)(m)].

OWNER INFORMATION

Please print clearly in ballpoint pen. Additional information on back page.

Owner Name	Street Address
City / State / Zip Code	Owner's Contact Person / Telephone Number

FACILITY INFORMATION

Facility Name	Street Address
City / Zip Code	County
Assembly Location	
Manufacturer	Model / Serial Number

Size _____ Assembly Type ☐ DC ☐ DC Detector

INITIAL TEST

First check	Second check
☐ Closed tight	☐ Closed tight
☐ Leaked	☐ Leaked
Static _____ PSID	Static _____ PSID

FINAL TEST

☐ Closed tight	☐ Closed tight
Static _____ PSID	Static _____ PSID

DETECTOR BYPASS ASSEMBLY INITIAL TEST

First check	Second check
☐ Closed tight	☐ Closed tight
☐ Leaked	☐ Leaked
Static _____ PSID	Static _____ PSID

DETECTOR BYPASS ASSEMBLY FINAL TEST

☐ Closed tight	☐ Closed tight
Static _____ PSID	Static _____ PSID

ASSEMBLIES IN FIRE PROTECTION SYSTEMS

Note: Include hose stream demand where applicable

Forward Flow Test

Designed flow rate _____ GPM Actual flow rate _____ GPM

Indicating Control Valves

☐ No. one control valve open ☐ No. two control valves open Valve supervision: ☐ Tamper switch ☐ Locked

Part (s) Replaced/Comments _____

I HEREBY CERTIFY THE TEST RESULTS ARE TRUE AND THE TEST WAS CONDUCTED BY ME PERSONALLY.

Tester Name (print) _____ Registration No. _____ Time of Day _____

Tester Signature _____ Phone No. _____ Date _____

White Copy – Owner, Pink Copy – Purveyor, Yellow Copy - Tester

Owner Information

The backflow preventer is a mechanical device designed to protect the potable water supply system from being contaminated. There is a physical connection to equipment or water of either unknown or questionable quality, thereby requiring the installation of the backflow preventer. In order to ensure that this device is working as designed, it must be periodically tested.

A test shall be conducted on each backflow preventer prior to it being put into service, after any repairs, and a minimum of once a year thereafter.

It is the responsibility of the owner to make sure the device is tested. The test shall be performed by a department registered Cross Connection Control Device tester.

Owner's Contact Person: The owner's contact person is the name of the person responsible for the backflow preventer maintenance and records. (**Note: Please provide full name.)**

Old Valve Replacement Information

If this test is for a replacement valve, please include all information for the replacement valve on this form. The manufacturer, model no., serial no., size, and the assembly type of the "old" valve must included on the comment line of this form.

Double Check Valves and Double Detector Check Valves Installed in Fire Protection Systems
A copy of this completed test must be attached to or located near the double check valve or double detector check valve.

Minimum Requirements for Passing Test

DC and DC Detector

- The first check must close tight, and have a minimum static 1 PSID.
- The second check must close tight, and have a minimum static 1 PSID.

Do not send a copy of this report to the Industry Services Division. Copies of this report shall be distributed to the following: owner, purveyor, and tester.